

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 975/A2, 2024

Dated: 26.4.2024

It is certified that an inspection team headed by M. Munugesan

(Name of Officers with designation) from Block Health Supervisor

inspected the Public Health Department, Ammaiyamayakanur

(Name & Address of the school) on 26.4.2024 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. ECI-WA-2024-1 / dated 22.4.2024

of Enviro Care India Pvt Ltd (PHED Lab) certified that

the M/s. Damien Public School (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till one year.

Signature with Seal:

Name

Designation

Name & Address of the Office / Department

M. Munugesan
Block Health Supervisor
Govt Primary Health Centre
Ammaiyamayakanur
Dindigul Dt. 201...

To

Correspondent
M/s. Damien Public School (CBSE)

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



22.04.2024

To

M/s. Damien Public School (CBSE)

Diravianagar,
Nilakottai-624 208,
Dindigul District.

Dear Sir / Madam

Sub: Submission of Analysis Report - Reg

Ref: With reference to the IWO Date: 16/04/2024


Thank you for providing the opportunity to service you in the field of Water testing. We have received the Water Sample from your factory premises on April 2024. The following analysis reports are enclosed herewith for your kind reference. Kindly acknowledge the receipt of reports and invoice.

a) Water Sample (1 no)

We welcome your valid enquires / requirements. Please feel free to contact us in case of any further assistance. We look forward to your valid order further.

Thanking you

For Enviro Care India Private Limited


Authorized Signatory

Enclosure:

1. Test Report
2. Invoice No: _____



TEST REPORT

Accredited by NABL (Chemical & Biological)

Report No :	ECI-WA-2024/04/121	Report Date :	22.04.2024
Customer Name & Address	M/s. Damien Public School (CBSE) Diravianagar, Nilakottai-624 208, Dindigul District.		
Customer Reference :	IWO Date: 16/04/2024	Sample Reference No :	ECI-WA-2024/04/121
Sample Drawn By :	ECI	Sample Received On :	18.04.2024
Sample Collected Date :	16.04.2024	Test Commenced On :	18.04.2024
Qty of Sample Received :	2 L	Test Completed On :	22.04.2024
Sample Description :	Water	Sampling Method :	IS 3025:Part 01 & IS 1622
Sample Mark:	Drinking Water		

S.No	PARAMETERS	UNITS	RESULTS	TEST METHOD	Max. Acceptance Limits of IS:10500
Chemical Parameters:					
1.	Calcium(as Ca)	mg/L	61	IS 3025:Part 40	75
2.	Chlorides(as Cl)	mg/L	55	IS 3025:Part 32	250
3.	Iron (as Fe)	mg/L	BDL (DL= 0.01)	IS 3025 Part 53	0.3
4.	Lead(as Pb)	mg/L	BDL (DL = 0.01)	IS 3025 Part 47	0.01
5.	Magnesium (as Mg)	mg/L	17	IS 3025 Part 46	30
6.	pH Value @ 25°C	--	7.3	IS 3025:Part 11	6.5 - 8.5
7.	Residual Free Chlorine (RFC)	mg/L	< 0.1	IS 3025 Part 26	0.2
8.	Sulphates (as SO ₄ ²⁻)	mg/L	17	IS 3025 Part 24	200
9.	Total Alkalinity (as CaCO ₃)	mg/L	192	IS 3025 Part 23	200
10.	Total Dissolved Solids(TDS) @ 180°C	mg/L	424	IS 3025:Part 16	500
11.	Total Hardness(as CaCO ₃)	mg/L	190	IS 3025 Part 21	200
12.	Total Suspended Solids(TSS) @105°C	mg/L	< 1.0	IS 3025 Part 17	NA
13.	Turbidity	NTU	< 0.5	IS 3025:Part 10	1.0
Microbiological Parameters:					
14.	Escherichia coli(MPN)	MPN/100ml	< 2.0	IS: 1622	Absent
15.	Total coliform(MPN)	MPN/100ml	< 2.0	IS:1622	Absent

Opinion: As Per IS 1622 MPN Table (Table-4) <2 Can be taken as absent. The above sample meets the requirements of drinking water quality (as per IS: 10500) with respect to the parameters tested. NA – Not Applicable
BDL –Below Detectable Limit, DL – Detectable Limit
End of Report --->

Verified By : *S.d.*
Block Health Supervisor
 Govt Primary Health Centre
 Ammalanaickanur
 Dindigul Dt -624 208

For ENVIRO CARE INDIA PRIVATE LIMITED
 (Laboratory Division)
Pravin
 Authorized Signatory

#43, 2nd Street, Harvey Nagar, Arasaradi, Madurai - 625016 | Tel: 0452 4355103
 Email: lab@envirocareindia.com | Web: www.envirocareindia.com

- Note:**
- The results relate only to this item tested.
 - Any Correction not attested shall invalidate this report.
 - Report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
 - Unless informed by customer, the test items will not be retained for more the 15 days from date of issue of test report.
 - Total liability of our laboratory is limited to the invoice amount.
 - Any dispute arising out of this report is subjected to Madurai Jurisdiction Only.

